



ALFRED NZO
DISTRICT MUNICIPALITY

Infrastructure Development and Municipal Services SPECIFICATION

Enquiries: K Gogela


Ext: 5264

The order to be issued as per the specification below:

ITEM NO.	DESCRIPTION OF ITEM	QUANTITY
1.	Preparation	
1.1	Sugar wash of both reservoir walls (2 x 20 KL)	2
1.2	Apply Sika sealant in 3 coats	2
1.3	Apply a bitumen application on all joints	2

NB ALL BIDDERS SHOULD BE REGISTERED WITH A MINIMUM OF IGB ONLY

K Gogela





ALFRED NZO
DISTRICT MUNICIPALITY

Infrastructure Development and Municipal Services SPECIFICATION

1.4	Perform a 12 hour step test after sealing process has completed. Diesel to run pumps must be provided by the service provider.	2
-----	---	---


Requested by
K Gogela – Area WSP Manager (Umzimvubu)


Recommended by
M Ntamane – Acting WSP Manager

Approved / ~~Not Approved~~


Senior Manager: IDMS
X. Masiza