



**ALFRED NZO**  
DISTRICT MUNICIPALITY

# Infrastructure Development and Municipal Services SPECIFICATION

Enquiries: K Gogela


Ext: 5264

The order to be issued as per the specification below:

ITEM NO.	DESCRIPTION OF ITEM	QUANTITY
<b>1.</b>	<b>Storage</b>	
1.1	Cast 2 x 6 x 100mm concrete slab with smooth steel floated finish. 15MPA concrete strength. Install tie down points cast into concrete to hold 6 x 5000 liters Jojo tanks. Tanks to be supplied by the Municipality.	1
<b>2</b>	<b>Spring</b>	
2.1	Construct spring weir with box 1.2 x 1 x 0.800mm from 10MPA strength concrete. Spring box to include ANDM approved cast iron lockable frame and lid with padlock.	1
<b>3</b>	<b>Generator</b>	
3.1	Supply and install diesel driven generator to run submersible pump. Fit Nist control box on pump control. Generator to accommodate additional fuel storage of 1000 litres with shut off valve and level indicator to check fuel level.	1

*JB* ALL BIDDERS SHOULD BE REGISTERED TO CIDB WITH A MINIMUM OF 1GB ONLY

*K*  
*Gogela*






**ALFRED NZO**  
DISTRICT MUNICIPALITY

# Infrastructure Development and Municipal Services SPECIFICATION

<b>4</b>	<b>Testing</b>	
4.1	Allow sum for testing of the scheme and fitting of 20mm bib taps on 16 x standpipe connections. Sum should include for excavation and repair to HDPE pipe leaks	1



Requested by  
**K Gogela – Area WSP Manager (Umzimvubu)**



Recommended by  
**M Ntamane – Acting WSP Manager**

Approved / Not Approved



Senior Manager: IDMS  
**X. Masiza**